



TECHNICAL POLICY

13 – 05 Sprinklers in Stair Enclosures

Original Issue: February 1985
Revised: April 2006

1. Sprinklers are required to provide coverage of all of the accessible floor area at the lowest stair level.
2. Sprinklers are required under all combustible stairs and landings.
3. Sprinklers are to be installed at each floor level landing when stairs of combustible construction have gypsum board on the bottom and sides.