



MINNEAPOLIS
DEPARTMENT OF PUBLIC WORKS

DRAWN: TDS

DATE: 11/19/13

APPROVED: RCE

DATE: 11/19/13

HYDRANT BRANCH INSTALLATION

STANDARD PLATE NO. WATR-1000A-R2

NOTES:

- 1. OPERATING NUT SHALL BE FURNISHED WITH L.H. (COUNTER CLOCKWISE) OPENING.
- 2. HYDRANTS SHALL MEET THE REQUIREMENTS IN THE SPECIAL PROVISIONS.
- 3. USE EBAA MEGALUGS OR APPROVED EQUAL FOR THRUST RESTRAINT ON ALL JOINTS OF HYDRANT BRANCH.