



**NOTES:**

1. HYDRANTS SHALL MEET THE REQUIREMENTS IN THE SPECIAL PROVISIONS.
2. HYDRANTS PROVIDED BY WTDS.
3. USE EBAA MEGALUGS OR APPROVED EQUIVALENT FOR THRUST RESTRAINT ON ALL JOINTS OF HYDRANT BRANCH.
4. OMIT CICHY BLOCK IF NEW CONSTRUCTION IS PROPOSED FROM WATERMAIN.

NOT TO SCALE



DRW: JAS	DATE: 2/22/16
APP: CMD	DATE: 2/22/16

HYDRANT BRANCH AND  
VALVE BOX

STANDARD  
PLATE  
NO.  
WATR-1000