



NOTES:

1. HYDRANTS SHALL MEET THE REQUIREMENTS IN THE SPECIAL PROVISIONS.
2. HYDRANTS PROVIDED BY WTDS.
3. USE EBAA MEGALUGS OR APPROVED EQUIVALENT ON ALL JOINTS OF HYDRANT BRANCH.
4. OMIT CICHY BLOCKS IF NEW CONSTRUCTION IS PROPOSED FOR WATERMAIN.
5. SEE WATER-3000 FOR MANHOLE REQUIREMENTS.



DRW: JAS	DATE: 2/22/16
APP: CMD	DATE: 2/22/16

HYDRANT BRANCH GATE
MANHOLE

STANDARD
PLATE
NO.
WATR-1001

NOT TO SCALE