



NOTE:

1. USE EBAA MEGALUGS OR APPROVED EQUIVALENT ON ALL JOINTS THROUGH PIPE TRANSITION.
2. INSULATION NOT ALLOWED TO MEET REQUIRED SEPARATION.
3. FOLLOW CITY GUIDANCE AND TEN STATE STANDARDS FOR HORIZONTAL SEPARATION REQUIREMENTS.
4. CENTER PIPE AT LOCATION OF CROSSING.
5. CONCRETE ENCASEMENT CLEARANCE SHALL BE 18 INCHES TO TOP OF ENCASEMENT.
6. SEE DETAIL PLATES 4000 - 4002 FOR CONCRETE ENCASEMENT.

NOT TO SCALE



DRW: JAS

DATE: 4/12/16

APP: CMD

DATE: 4/12/16

TYPICAL WATERMAIN OFFSETS

STANDARD
PLATE
NO.
WATR-2001