



- NOTES:
- ① EXPANSION MATERIAL REQUIRED (SEE MNDOT SPEC BOOK, 2301.3K JOINT CONSTRUCTION). FIRST SECTION NEXT TO COMMERCIAL DRIVEWAY OR ALLEY 6" THICK. 1/2" THICK EXPANSION JOINTS AT 30' INTERVALS (MAXIMUM). EXPANSION TO BE USED WHEN SIDEWALK ABUTS:
    - BUILDING,
    - CURB,
    - OTHER PAVEMENTS INDICATED ON GRAPHIC ABOVE.
  - ② CONTRACTION JOINT TO BE CENTERED ON SIDEWALK WIDER THAN 9'. CONTRACTION JOINT TO BE PLACED EVERY 6' OR LESS.
  - ③ DEVELOPMENT PROJECTS SHALL PLACE AND COMPACT 4" OF CLASS 5 AGGREGATE UNDER THE NEW SIDEWALK.
  - ④ SLOPE TOWARD ROADWAY, 3/16" PER FT. TYPICAL, 1/4" PER FT. MAX. AS CONSTRUCTED.

	DRW: JFC	DATE: 1/4/16	TYPICAL SIDEWALK AND DRIVEWAY CONSTRUCTION	STANDARD PLATE NO. ROAD-2003-R1
	APP: JSH	DATE: 12/30/15		