



NOTES:

1. ONE OR MORE GROUND RODS MAY BE REQUIRED.
 2. CABINET ANCHORS ARE HILTI KWIK BOLT II WEDGE ANCHOR OR EQUAL, 4 PER CABINET, 1/2" x 4 1/2" STAINLESS STEEL (#304) FULL THREADED.
- ⚠** KEEP SERVICE FEED TO LEFT OF BARRIER.

NO SCALE



MINNEAPOLIS
DEPARTMENT OF PUBLIC WORKS

DRAWN: LPK

DATE: 1/1/11

APPROVED: DRP

DATE: 1/1/11

FOUNDATION - ST. LIGHT/SIGNAL
SERVICE CABINET

STANDARD
PLATE
NO.
TRAF-3094