



Minneapolis Water Works

Monthly Plant Effluent Water Analysis for:

November 2018

Physical and Chemical Water Quality

	<u>Plant Effluent Average Value</u>
Temperature, River Water Average (°C)	3.9
Total Organic Carbon (ppm* as C)	4.66
Total Dissolved Solids (ppm)	142
Turbidity (NTU)	0.05
Alkalinity-Total (ppm as CaCO ₃)	57
Ammonia Nitrogen (ppm as N)	0.87
Chlorine Residual (ppm Cl as Cl ₂)	4.0
Fluoride-F (ppm as F)	0.74
pH	8.91
Nitrate - NO ₃ (ppm as N)	0.56
Nitrite - NO ₂ (ppm as N)	<0.015
Phosphate-PO ₄ (ppm as PO ₄)	1.09
Sulfate - SO ₄ (ppm as SO ₄)	27.7
Total Hardness (grains per gallon) EDTA method	5.50
Total Hardness (ppm as CaCO ₃) EDTA method	94

Chemical Water Quality - Inorganic Metals

	<u>Plant Effluent Average Value</u>
<u>Chemical Element</u>	
Aluminum-Al (ppm as Al)	0.01
Arsenic-As (ppm as As)	Not Detected
Cadmium-Cd (ppm as Cd)	Not Detected
Calcium-Ca (ppm as Ca)	31.0
Chloride-Cl (ppm as Cl)	23.6
Chromium (ppm as Cr)	<0.01
Copper-Cu (ppm as Cu)	<0.01
Iron-Fe (ppm as Fe)	Not Detected
Lead-Pb (ppm as Pb)	Not Detected
Magnesium-Mg (ppm as Mg)	1.76
Manganese-Mn (ppm as Mn)	<0.01
Sillca-Si (ppm as Si)	9.76
Sodium-Na (ppm as Na)	12.0
Zinc-Zn (ppm as Zn)	<0.01

*ppm = parts per million